

Lakewood Volunteer Fire Department
2627 Shadyside Road
St. Albans, WV 25177
304-727-2451

RE: Emergency Back-up Generator

Date: September 17, 2010

Bid Opening: Bids must be received on or before Monday, October 18, 2010 7:15 pm at the Lakewood VFD 2627 Shadyside Road St. Albans, WV 25177

Instructions to Bidders:

Please use this cover sheet for your bid

5. Bids must be received in a sealed envelope with date and time of the bid opening on the outside of the envelope. Faxed bids will NOT be accepted.
6. Bid must be F.O.B. Delivery Point, unless otherwise indicated in proposal.
7. All bids should be signed and in ink, showing all facts and the total amount of the bid.
8. The Lakewood VFD reserves the right to accept or reject, in part or in whole, any bid submitted, whichever is in the best interest of the Lakewood VFD.

Item No.	Description	Amount
1.	Emergency Back-up Generator for Lakewood VFD station, labor, material and installation	

Vendor Name _____ Date _____

Signature _____ Telephone _____

Address _____

E-mail Address _____

Specifications

Item: Emergency Back-up Generator

Location: Lakewood Volunteer Fire Dept.
2627 Shadyside Road
St. Albans, WV 25177

Contact: Michael L. Matthews, Chief
Lakewood VFD
2627 Shadyside Road
St. Albans, WV 25177

Bid Opening:

Bids must be received in a sealed envelope, with the date and time of the bid opening on the outside of the envelope, on or before Monday, October 18, 2010 7:15 pm, at the Lakewood VFD, 2627 Shadyside Road, St. Albans, WV 25177. Faxed bids will not be accepted.

Specifications:

The following specifications are intended to describe firefighting equipment for the Lakewood VFD and the details contained in these specifications are not designed to exclude any vendor from bidding, but are offered as a means of describing the needs of the Lakewood VFD. Where brand names may be used, the words "or equal" are assumed to follow. Once bids are unsealed, all bid documents become public record. The Lakewood VFD reserves the right to reject any and / or all bids and to waive any informality in bidding. All specifications are minimum requirements:

Emergency Back-up Generator

- 48 KW generator
- Aluminum housing
- Operate on natural gas
- High coolant temperature shutdown
- Exercise timer
- Hour meter
- 1800 RPM engine
- 200 Amp
- Secure Mounting
- Delivery and installation
- 1 Year service contract
- All electrical supplies
- All natural gas line supplies